

CORSO TICASS

Energy Saving in LIGHTING SYSTEMS

ING. RICCARDO BIGGI



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

CORSO TICASS

Interior Lighting in a industrial building

EXAMPLE OF A GARAGE FOR REPAIR AND DEPOSIT OF ROAD PUBBLIC TRANSPORT VEHICLES



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

PROJECT REQUESTS

Reducing the energy consumed by the lighting system through the replacement of lighting currently installed without modification to the plant system




Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

CORSO TICASS

Input Data



CURRENT STATE LAY OUT



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Input Data

| Corpo illuminante | Lampada | Tipologia | Quantità |
|-------------------|---------|-----------|----------|
| Plafoniera | Neon | 1x18 | 20 |
| Plafoniera | Neon | 2x18 | 130 |
| Plafoniera | Neon | 4x18 | 8 |
| Plafoniera | Neon | 1x36 | 56 |
| Plafoniera | Neon | 2x36 | 80 |
| Plafoniera | Neon | 1x58 | 21 |
| Plafoniera | Neon | 2x58 | 102 |
| Lampada | Alogena | 1x200 | 2 |
| Riflettore | HG | 1x125 | 83 |
| Riflettore | JM | 1x250 | 93 |
| Riflettore | JM | 1x400 | 4 |
| Proiettore | NA | 1x90 | 6 |

CURRENT STATE CONSISTENCY



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Preliminary investigations

FOTO 3 – Insieme Capannone (Riflettori Industriali e Plafoniere stagne su setto di separazione)





FOTO 4– Insieme Capannone (Riflettori Industriali e Plafoniere stagne su setto di separazione)




RELIEF

Preliminary investigations




CURRENT LIGHTING FIXTURE

Preliminary investigations




CURRENT LIGHTING FIXTURE

Preliminary investigations




CURRENT LIGHTING FIXTURE

Lighting Calculations




CURRENT STATE $E_m = 300$ lux

Lighting Calculations



CURRENT STATE $E_m = 300 \text{ lux}$


Substitutions




PROJECT LIGHTING FIXTURE

Substitutions

Plafoniera WT 120 C – 17W 20W 29W 38W 57W LED – Philips



650mm x 90mm




Semiplani C

180.0 — 0.0


270.0 — 90.0

Flusso 1800.00 lm
Massimo 335.90 cd/km
Posizione C=0.00 G=32.00
Rendimento: 100.14%
Data: 28-02-2013
Doppia Simmetria



PROJECT LIGHTING FIXTURE

Substitutions



PROJECT LIGHTING FIXTURE

Substitutions

| Corpo Illuminante Stato Attuale | Corpo Illuminante Proposto LED |
|---------------------------------|-------------------------------------|
| Plafoniera 1x18 FL | Plafoniera LED WT 120 C - 18S 17 W |
| Plafoniera 2x18 FL | |
| Plafoniera 1x36 FL | Plafoniera LED WT 120 C - 22S 20 W |
| Plafoniera 2x36 FL | Plafoniera LED WT 120 C - 34S 29 W |
| Plafoniera 1x58 FL | Plafoniera LED WT 120 C - 40S 38 W |
| Plafoniera 2x58 FL | Plafoniera LED WT 120 C - 60S 57 W |
| Plafoniera 4x18 FL | Plafoniera RC 125B - 34S 41 W |
| Industriale 1x125 HG | Riflettore LED BY 120 P 100 W |
| Industriale 1x250 JM | |
| Industriale 1x400 JM | Riflettore LED BY 121 P 198 W |
| Proiettore 1x90 NA | Proiettore LED BVP 120 - 80 NW 80 W |
| Proiettore 1x200 INC | |


PROJECT LIGHTING FIXTURE



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Lighting Calculations



PROJECT STATE $E_m = 305 \text{ lux}$



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Calculation of the annual operating hours

$$H_y = H_g \times GG_y$$

Where:

H_g Day hour operation (ex. 8 h)

GG_y Days year operation (ex. 365 h)

H_y Annual operating hours (ex. 8760 h)



Calculation of annual energy

$$E_y = P_l \times H_y$$

Dove:

P_l Power of lighting fixture [kW]

H_y Annual operating hours

E_y Annual Energy [kWh/year]

Calculation of the annual energy cost

$$C_y = E_y \times C_{\text{kWh}}$$

Dove:

E_y Annual Energy [kWh/year]

C_{kWh} kWh Cost [Euro/kWh] (ex. 0,16)

C_y Annual Energy Cost [Euro/year]

Conclusions

| Summary of project | Current State | Project State |
|-----------------------------------|------------------|------------------|
| N° of lighting fixture[n.] | 605 | 605 |
| Max Power of lighting system [kW] | 62,61 [kW] | 31,96 [kW] |
| Annual Energy Cost [kWh/year] | 521.977,88 [kWh] | 267.453,92 [kWh] |
| Annual Energy Cost [Euro/year] | 83.516,46 [Euro] | 42.792,63 [Euro] |

49% saving
40.723,83 Euro/year saved

CORSO TICASS

Outdoor lighting

EXAMPLE OF PUBLIC LIGHTING SYSTEM FOR LITTLE AMMINISTRATION



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

PROJECT REQUESTS

Reducing the energy consumed by the lighting system through the replacement of lighting currently installed without modification to the plant system




Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Data Input

INQUADRAMENTO PLANIMETRICO DEI SISTEMI DI ILLUMINAZIONE ESISTENTI
CENSIMENTO LP - ROSSIGLIONE SUPERIORE
(scala 1:5000)



CENSUS LIGHTING FIXTURE




Via Caffa 12 C - 16121 Genova
Tel. +39 010 8692345 mail: info@bms-studio.it

CORSO TICASS

Data Input

STRALCIO FRAZIONE GARRONE



CENSUS LIGHTING FIXTURE



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Data Input

QUADRO H00

Frazione Garrone - P.I. 007 (c.ill. da H01 a H13)

| TAG ID | Localizzazione VIA/PIAZZA | Tipologia SOSTEGNO | N. APPAR. | ALTEZZA APPARECCHIO | INTERD. SOSTEGNI | TIPO E POTENZA LAMPADA | TOTALE POTENZA | LINEA INTERRATA/AEREA | | | |
|---|---------------------------|--------------------|-----------|---------------------|------------------|------------------------|----------------|-----------------------|----------|-------------|-------|
| | | | | | | | | | sostegno | apparecchio | linea |
| H01 | Frazione Garrone - | F | 1 | 8 | | VM125 | 125 | I | 2/3 | 2 | 2 |
| H02 | Frazione Garrone - | F | 1 | 8 | 20 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H03 | Frazione Garrone - | F | 1 | 8 | 25 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H04 | Frazione Garrone - | F | 1 | 8 | 30 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H05 | Frazione Garrone - | F | 1 | 8 | 25 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H06 | Frazione Garrone - | F | 1 | 8 | 27 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H07 | Frazione Garrone - | F | 1 | 8 | 25 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H08 | Frazione Garrone - | F | 1 | 8 | 30 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H09 | Frazione Garrone - | F | 1 | 8 | 30 | VM125 | 125 | In tubazione | 2/3 | 2 | 2 |
| H10 | Frazione Garrone - | F | 1 | 8 | 30 | VM125 | 125 | In tubazione | 2/3 | 2 | 2 |
| H11 | Frazione Garrone - | F | 1 | 8 | 30 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H12 | Frazione Garrone - | F | 1 | 8 | 30 | VM125 | 125 | I | 2/3 | 2 | 2 |
| H13 | Frazione Garrone - | F | 1 | 8 | 40 | VM125 | 125 | I | 2/3 | 2 | 2 |
| TOTALI | | | 13 | | | | 1625 | | | | |
| Totale potenza effettiva assorbita ai capi del QE | | | | | | | 1788 | | | | |

CENSUS LIGHTING FIXTURE



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Data Input

| Definizione del Punto Luce | Quantità |
|--|------------|
| Corpi Illuminati artistici equipaggiati con lampade ai vapori di mercurio da 125W | 133 |
| Globi equipaggiati con lampade ai vapori di mercurio da 125W e 50W | 62 |
| Corpi illuminati equipaggiati con lampade ai vapori di mercurio da 125W e 250W | 185 |
| Armatore stradali equipaggiate con lampade al sodio alta pressione da 100W e 250W | 34 |
| Corpi illuminanti in buono stato di conservazione equipaggiati con lampade al sodio da 100W, 150W e 250W | 55 |
| Corpi illuminanti equipaggiati già con lampade agli ioduri metallici e/o led di varie potenze | 27 |
| Totale Punti Luce | 496 |




CENSUS LIGHTING FIXTURE



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Preliminary Considerations



Street lighting fixture emission

Calculation of Total Output Luminous Flux

$$\Phi_{OSA} = LOR \times \Phi_L$$

Dove:

LOR Lighting Output Ratio (ex. 70%)

Φ_L Source Luminous Flux [lm]

Φ_{OSA} Total Output Luminous Flux [lm]

Calculation of Util Luminous Flux

$$\Phi_{\text{OUSA}} = \text{DLOR} \times \Phi_{\text{L}}$$

Where:

DLOR Down Load Output Ratio (ex. 40%-45%)

Φ_{L} Source Luminous Flux [lm]

Φ_{OUSA} Util Luminous Flux [lm]

Luminous Flux of discharge lamp

| Id. di Progetto | | Flusso Luminoso di Lampada [lumen] |
|---|-------|------------------------------------|
| Potenza | Tipo | |
| Lampade Sodio Alta Pressione ed Ioduri Metallici | | |
| 1000 | NA/JM | 80000 |
| 400 | NA/JM | 48000 |
| 250 | NA/JM | 27000 |
| 150 | NA/JM | 14000 |
| 100 | NA/JM | 10000 |
| 70 | NA/JM | 6500 |
| 35 | JM | 3300 |
| Lampade Vapori di Mercurio | | |
| 400 | QE | 22000 |
| 250 | QE | 13000 |
| 125 | QE | 6300 |
| 80 | QE | 3700 |
| 50 | QE | 1800 |
| Lampade Sodio Bassa Pressione | | |
| 295 | NB | 32000 |
| 135 | NB | 21500 |
| 90 | NB | 13000 |
| 55 | NB | 7400 |
| 35 | NB | 4500 |

Luminous Flux of LED

| Codice Identificativo | Lumen emessi | Watt totali | Efficienza [lm/W] |
|-----------------------|--------------|-------------|-------------------|
| STR253LD | 30.650 | 253 | 121 |
| STR169LD | 20.434 | 169 | 121 |
| STR84LD | 10.089 | 84 | 120 |
| STR63LD | 7.729 | 63 | 123 |
| STR42LD | 5.196 | 42 | 124 |
| STR28LD | 3.649 | 28 | 130 |
| STR14LD | 1862 | 14 | 133 |

Substitutions

| Potenza Lampada Attuale | Tipo | Flusso Luminoso Utile | Potenza LED | Flusso Luminoso LED | Tipo |
|-------------------------|-------|-----------------------|-------------|---------------------|----------|
| 400 | NA/JM | 20400 | 169 | 20434 | STR253LD |
| 250 | NA/JM | 11475 | 126 | 15133 | STR169LD |
| 150 | NA/JM | 5950 | 63 | 7729 | STR84LD |
| 100 | NA/JM | 4250 | 42 | 5196 | STR63LD |
| 70 | NA/JM | 2763 | 28 | 3649 | STR42LD |
| 400 | QE | 9350 | 126 | 15133 | STR126LD |
| 250 | QE | 5525 | 63 | 7729 | STR84LD |
| 125 | QE | 2678 | 28 | 3649 | STR42LD |
| 80 | QE | 1573 | 28 | 3649 | STR28LD |
| 50 | QE | 765 | 28 | 3649 | STR14LD |
| 295 | NB | 13600 | 126 | 15133 | STR253LD |
| 135 | NB | 9138 | 84 | 10089 | STR126LD |
| 90 | NB | 5525 | 63 | 7729 | STR84LD |
| 55 | NB | 3145 | 28 | 3649 | STR42LD |
| 35 | NB | 1913 | 28 | 3649 | STR28LD |



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Calculation of annual energy and Calculation of the annual energy cost

are the same but:

$$H_y = 4200 \text{ [h]}$$

$$C_{\text{kWh}} = 0,21 \text{ [Euro/kWh]}$$



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it

Conclusions

| Summary of project | Current State | Project State |
|-----------------------------------|------------------|------------------|
| N° of lighting fixture[n.] | 496 | 496 |
| Max Power of lighting system [kW] | 72,29 [kW] | 32,25 [kW] |
| Annual Energy Cost [kWh/year] | 328,826,40 [kWh] | 156.433,20 [kWh] |
| Annual Energy Cost [Euro/year] | 69.053,54 [Euro] | 32.850,97 [Euro] |

52% saving
36.202,57 Euro/year saved



Via Caffa 12 C - 16121 Genova

Tel. +39 010 8692345 mail: info@bms-studio.it